

# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**DEHN + SÖHNE GmbH + Co.KG**

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: SURGE PROTECTION DEVICE (DEHN)

DEHNGUARD S SERIES: DGS275(FM); DGS75(FM); DGS150(FM); DGS320(FM); DGS385(FM); DGS440(FM); DGS600(FM);  $U_c = 75V, 150V, 275V, 320V, 385V, 440V, 600V; I_{max} = 30kA, 40kA, U_p \leq 0.4kV, 0.7kV, 1.25kV, 1.5kV, 1.75kV, 2kV, 2.5kV, 50/60Hz$

Test Laboratory:

OVE, CTI-VIENNA

Test Report No(s): CTI-PA 2972-1 to 9

RCC No: 1802029

In accordance to(Standards):

IEC 61643-11: 2011 (E,d1)

Period of Validity

12/02/2018 to 12/02/2021

NRCS Electro-Tech General Manager

DATE

19 February 2018

