

CERTIFICATE OF COMPLIANCE

Certificate Number 20181031-E201573
Report Reference E201573-20060427
Issue Date 2018-OCTOBER-31

Issued to: WAGO Kontakttechnik GmbH & Co. KG
Hansastrasse 27
32423 Minden GERMANY

**This is to certify that
representative samples of**

GROUNDING AND BONDING EQUIPMENT
Listed Spring Action Grounding wire connectors, Cat. Nos.
222-412 through 222-415, & 222-462 through 222-468. Cat.
Nos. 221-412, 221-413, 221-415. Cat. Nos. 221-612, 221-
613, 221-615.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Grounding and Bonding Equipment, UL 467 and CAN/CSA
C22.2 No. 41-13.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



NOTIFICATION OF TEST RESULTS

Issued to: Wago-Kontakttechnik GmbH & Co. KG
Hansastraße 27, 32423 Minden/Westfalen, Germany

For the product: Splicing wire connectors

Trade name: WAGO

Type/Model: 221

Manufactured by: Wago-Kontakttechnik GmbH & Co. KG
Hansastraße 27, 32423 Minden/Westfalen, Germany

Ratings: 450 V, 32 A, 4 mm²
0,14 mm² flexible, 0,2 mm² – 4 mm² flexible and rigid

Additional information: This NTR replaces NTR NL-7642 issued on 19 October 2017, due to the fact that new types are added

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard
EN 60998-1:2004, EN 60998-2-2:2004

As shown in the Test Report
2224732.50


This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body, which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body.

Arnhem, 27 August 2018

Number: NTR NL-7698

DEKRA Certification B.V.



H.R.M. Barends
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

CCA
CENELEC CERTIFICATION AGREEMENT
ACCORD DE CERTIFICATION DU CENELEC

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396