

RCC
(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO
ACDC DYNAMICS (Pty) Ltd
IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: SURGE PROTECTIVE DEVICE (ACDC)
KM20-40;
L/N-PE; $U_c = 275V_{\sim}$, $I_n = 40kA$; $I_{max} = 60kA$; $U_p = 1.5kV$;
IP20

Test Laboratory:
Guangdong LNP Electrical Testing Technology Co., Ltd
In accordance to (Standards):
IEC 61643-11:2011 (Ed1)

Test Report No: P2212091055

RCC No: 2304025

 ACTING

NRCS Electro-Tech General Manager

Period of Validity
24/04/2023 to 24/04/2026

DATE 26-04-2023

