

Product SPECIFICATION SHEET



BUSBAR MOUNTED NH FUSE DISCONNECTOR

DNH18-250A~630A

Performance parameters

Rated working current	Rated working voltage	Rated insulation voltage	Conventional heating current	Rated impulse withstand voltage
250A 250A 200A	AC400V AC500V AC690V	1000V	250A 250A 200A	12kV
400A 400A 315A		1000V	400A 400A 315A	12kV
630A 630A 500A		1000V	630A 630A 500A	12kV

BRANCH CONTACT DETAILS

Johannesburg 010 202 3300
Germiston 011 418 9600
Cape Town 021 510 0710
Pinetown 031 700 4215
Riverhorse 031 492 4800

NATIONAL CALL CENTRE

Sales 010 202 3400
Technical 010 202 3500

www.acdc.co.za

Product SPECIFICATION SHEET

Model Description

Rated current	Installation method	Operation method	Fuse/Isolation Knife	Auxiliary accessories	order number
250A	Fixed installation (punch holes)	Three-phase synchronous operation	with fuse	none	DNH18-250/3L
250A	Fixed installation (punch holes)	Three-phase independent operation	with fuse	none	DNH18-250/3S
250A	Fixed installation (punch holes)	Three-phase synchronous operation	with isolation knife	none	DNH18-250/3LD
250A	Mounting	Three-phase synchronous operation	with fuse	with auxiliary contacts	DNH18-250/311L
400A	Fixed installation (punch holes)	Three-phase synchronous operation	with fuse	none	DNH18-400/3L
400A	Fixed installation (punch holes)	Three-phase independent operation	with fuse	none	DNH18-400/3S
400A	Fixed installation (punch holes)	Three-phase synchronous operation	with isolation knife	none	DNH18-400/3LD
400A	Mounting	Three-phase synchronous operation	with fuse	with auxiliary contacts	DNH18-400/311L

BRANCH CONTACT DETAILS

Johannesburg 010 202 3300
Germiston 011 418 9600
Cape Town 021 510 0710
Pinetown 031 700 4215
Riverhorse 031 492 4800

NATIONAL CALL CENTRE

Sales 010 202 3400
Technical 010 202 3500

www.acdc.co.za

Product SPECIFICATION SHEET



Model Description

Rated current	Installation method	Operation method	Fuse/Isolation Knife	Auxiliary accessories	order number
630A	Fixed installation (punch holes)	Three-phase synchronous operation	with fuse	none	DNH18-630/3L
630A	Fixed installation (punch holes)	Three-phase independent operation	with fuse	none	DNH18-630/3S
630A	Fixed installation (punch holes)	Three-phase synchronous operation	with isolation knife	none	DNH18-630/3LD
630A	Mounting	Three-phase synchronous operation	with fuse	with auxiliary contacts	DNH18-630/311L

BRANCH CONTACT DETAILS

Johannesburg 010 202 3300
 Germiston 011 418 9600
 Cape Town 021 510 0710
 Pinetown 031 700 4215
 Riverhorse 031 492 4800

NATIONAL CALL CENTRE

Sales 010 202 3400
 Technical 010 202 3500

www.acdc.co.za